

UNIVERSAL LIFT POWER

POWER REQUIREMENTS

- Single phase 208VAC
 - 2 legs of 120, a neutral, and a ground with a NEMA L 14-20R receptacle labeled
- Each lift must be on a dedicated circuit
- Power **MUST** be operational at the time of installation in order to properly set the lift



*NEMA L14-20
Plug to be
SUPPLIED WITH LIFT



*NEMA L14-20
Receptacle to be
CUSTOMER SUPPLIED